



**THICKNESS:**  
**3/8", 1/2", 5/8",**  
**3/4", or 1"**

**NRC RANGE:**  
**up to .60**

Tackwall has moderate sound absorption qualities, and is constructed from a 28lb density mineral fiberboard made of 56% recycled material. It is appropriate for workstations, presentation areas, and anywhere a tackable surface would be of value. Tackwall is available with radius, beveled, mitered or square edges. The fabric covering is wrapped and returned on all sides, leaving tailored corners with no exposed edge.

**SCOPE**

This section includes all of the TACKWALL PANELS as manufactured by Quiet Concepts, Oak Park, Michigan as shown on drawings or referred to in these specifications.

**MATERIALS**

1. Tackwall Panels shall be constructed of lightweight mineral fiberboard core. It shall be dimensionally stable and non-combustible. Each unit shall be (3/8"), (1/2"), (5/8"), (3/4") or (1") in thickness, height and width as required. All edges shall be chemically hardened, to protect against damage. The corners shall be (square) or (rounded). The edges of the panel shall be (square), (beveled), (mitered) or (radius).
2. All panels shall be fabric wrapped on the face, all edges and a return on the back of not less than 1" with Quiet Concepts (standard fabrics and vinyls) or (manufacturer approved custom fabric).
3. Tackwall Panels shall be mounted using the following manufacturer's recommended mounting methods (mechanical z-clips), (construction adhesive), (pressure sensitive hook and loop), and (magnetic fasteners).
4. Tackwall Panels shall have a noise reduction coefficient of (.60) using ASTM C423-90A "Standard test method for sound absorption and sound absorption coefficients by the reverberation room method."
5. All components utilized in the construction of the Tackwall Panels meet Class A flame rating as tested per ASTM E84-94A standard test method for surface burning characteristics of building materials.

**PRODUCT HANDLING**

Protect Tackwall Panels from excessive moisture in shipment, and handling. Deliver in unopened bundles and store in dry place with adequate air circulation. Do not deliver material to building until "Wet Work" such as concrete and plaster have been completed and cured to a condition of equilibrium.

**PROJECT CONDITIONS**

1. Do not begin installation until spaces to receive Tackwall Panels have been enclosed and maintained at approximately the same humidity and temperature conditions as planned for occupancy. Conditions from 60 degrees F to 85 degrees F and not more than 80% R.H. in an enclosed building.
2. The contractor shall be responsible for the examination and acceptance of all surface and conditions prior to the wall panel installation.

**INSTALLATION**

1. All Tackwall Panels should be installed in accordance with the manufacturer's specifications and recommendations.
2. All necessary hardware and accessories for a complete job installation is to be furnished by the contractor.